

AUDIT REPORT OF SHRI PRAKASH TEXTILE. RAKHIYAL.

IN PRESENT OF

MR. SATISH G PATEL. (MECHANICAL ENGINEER OF PRAKASH TEXTILE)

MR. BHAVESH P THAKKAR (DIRECTOR ANJNEY TUBES INDIA)

MR. RAKESH PARIKH. (ASM ANJNEY TUBES INDIA)

PLANT SHUT DOWN ON WEDNESDAY 24.12.14

ELGI AIR COMPRESSOR.

22 KW. MACHINE

AVERY 2 MINUTES 40 SECOND LOAD.

IN 1 HOUR RESULT.

WHEN MACHINE IN UNLOAD CONDITION IN 1 HOUR 5 UNIT CONSUM

80 UNIT PER DAY LOSS IN UN LOAD POSITION

40 MINUTES – UNLOAD

20 MINUTES – LOAD

20 MINUTES *24 HOURS = 480 MINUTES (8 HOURS) LOSS

8 HOURS * 26 DAYS = 208 HOURS IN 1 MONTH. (26 DAYS)

IN 1 MONTH

208 HOURS * 22 UNIT = 4576 UNIT

80 UNIT*26 DAYS = 1040 UNIT

5616 UNIT PER MONTS.

5616 UNIT PER MONTH (26 DAYS)

***8 RS**

44928.00 RS ENERGY LOSS IN PER MONTH.


***12 MONTH**

539136 RS PER YEAR ENERGY LOSS IN 1 YEAR

SATISH G PATEL



RAKESH A PARIKH



BHAVESH P THAKKAR

